



## Facilities Management – Facilities Information Systems

### Alarm Issues

**Location: Vivarium**

**Date/Time: Wednesday, February 9, 2011 at 9:30 AM**

<b>Purpose of Meeting:</b>	This meeting is being held to discuss the current Vivarium BAS system and address known issues with alarms and control issues.	
<b>Facilitator/Coordinator:</b>	<b>Attendees:</b>	<b>Absentees:</b>
David Champion, BAS Analyst	Lance Anderson Norman Lefebvre Joe Johnson David Smith	

AGENDA				
Time	Topic	Attendees	Facilitators	
9:30 AM	Introduction <ul style="list-style-type: none"> <li>Agenda Overview</li> </ul>		DC	
9:45 AM	Items discussed Redundant humidity alarms AHU 3 and 4 shutdown sequence Power failure alarms JACE Version: are versions up to date on all JACEs Existing Soft JACE conversion to ITS server or virtual server Historical data needed for required reporting		DC	
10:15 AM	Questions/comments		DC	
	Meeting Outcome and actions to be completed Review Next Steps <ul style="list-style-type: none"> <li>Contact Schneider Electric: 1. Adjust humidity alarms to send first alarm only, and final OK notice. This used to work correctly. 2. Also have them check logic on AHU 3 and 4 shutdown sequence seems incorrect. Lance has existing PO for working on these issues. <b>(CALLED AND EMAILED JUSTIN PREVETTE – waiting for reply)</b></li> <li>JACE Alarms (COMM ALARMS) Check these for accuracy</li> <li>Called Paul Varavalai (7-7063) – Virtual Server for Soft JACE; he is no longer working in that group. Created helpdesk ticket with ITS for this.</li> </ul>		DC  NL	

Ticket # 149307: Asking ITS for recommendations about this proposal.

- I will follow up with Norm about VES database restore for History reports
- Norman will adjust humidity alarm setpoints

10:30 AM

*Adjourn*